



Southern Electricity Co.

شركة كهرباء الجنوب

# Tender No. (ELEC. 02/2009)

## Street Lighting Units and accessories

Sum(NIS)	
----------	--

Company.....

Signature.....



## **Instructions to bidders**

- *The bidder must submit a bank guarantee equivalent to 5% of the tender total value, valid for 90 days from the date of submission; otherwise, quotation will be rejected.*
- *Prices are in NIS excluding vat.*
- *Payments: 2 equal installments, 1st within 30 days from proof of delivery, 2<sup>nd</sup> within 60 days after final technical approval.*
- *Delivery: within (30) days from the date of accepting and informing the bidder of acceptance of quotation or according to the agreement after awarding the tender.*
- *Fines: 1% of the item price per week of delay and not more than 5% of total bid value.*
- *Prices including all charges up to the warehouses of SELCO.*
- *Bid document price is 100 NIS and will be paid when submitting the offer by the participants.*
- *Sunday August, 09<sup>th</sup> 2009 12:00 pm is the final time of receiving the offers at SELCo headquarter/financial dep. and in sealed envelopes.*
- *Discount at source certificate is required.*
- *Tender document could be obtained from SELCo website.*
- *For further information please do not hesitate to contact the procurement department:*

*Tel: 02 2283602/3*

*Fax: 02 2283601*

*Email: [abdelqader@selco.ps](mailto:abdelqader@selco.ps)*

*Website [www.selco.ps](http://www.selco.ps).*

**Basel Al Qadi**  
**Financial & Administrative Director**



**Tender (ELEC 02/2009)**  
**Street lights**

You are kindly requested to quote for the supply and delivery of street lighting units in the attachment schedule to our stores.

All street lighting fittings should comply with IEC Standard or other National Standard as approved by the Technical department.

Should the tender consider that they can offer any advantages to the purchaser by a modification to the specifications he may draw attention to such

By an attach mend document stating the change in the amount of his tender.

The purchaser does not bind himself to accept the lowest or any tender nor to assign any reason for the rejection of any tender, nor to purchase the whole of the equipment and materials specified.

***Test reports and catalogs shall be submitted with the tender.***

All street lighting luminaries shall be suitable for mounting on steel or wood poles and on the outside of buildings having either concrete block walls or concrete lintels. The lantern supports and brackets shall be made of aluminum alloy or galvanized steel tube or any equivalent material to the approval of the Engineer and suitable for the climatic conditions on site.

The whole of the lamp shall be housed within the luminaries. Lamp holders shall be non-sparking in normal operation and shall conform to the safety and interchange ability requirements of IEC 60238, when mounted in the luminaries. The design shall be such to prevent the lamp working loose in its holder under normal conditions of use, temperature variation or vibration.

The lantern shall consist of a pressure die cast aluminum alloy canopy or any equivalent material and an injection moulded vandal resistant bowl, integral control gear and 125 Watt mercury lamps & 150 Watt and 250 Watt SON lamps (High Pressure Sodium). This shall be suitable for operation at 230 volts, 50 Hertz. The mounting of the lantern shall be by means of suitable side entry spigot.

Mast arms shall be compatible for use with the mercury luminaries. Mast arms shall be made of aluminum or galvanized steel and shall provide upsweep and luminaries tilt for proper lighting performance. Mast arms shall be supplied in 1.5 meter nominal lengths. Mast arms shall be designed to withstand stresses due to winds, and shall be suitable for steel or wood pole mounting or wall mounting. Mast arms shall be supplied complete with all fixing clamps and accessories.

**Sample is compulsory requested for technical evaluation.**



Schedule of requested materials

Item	Description	Unit	Qty	Unit Price (NIS)	Total Price (NIS)
1	Complete Mercury lighting unit (125 w)	Set	500		
2	NYY or (equivalent) CU cable 2*1.5 mm <sup>2</sup> ,1000 v numbered longitudinally.(on one drum)	Meter	1500		
3	Internal lamp (mercury 125w)	Pcs	1000		